



301-382  
Operations Center  
5201 Grand Avenue  
Davenport, IA. 52807

P 563-322-8814 ext 3  
F 563-322-2190

<http://www.amwater.com/iaaw/>

REC'D

AUG 31 2010

APCO

August 26, 2010

Air and Waste Management Division  
U.S. Environmental Protection Agency  
901 N. 5<sup>th</sup> Street  
Kansas City, KS 66101  
Attn: Director

RE: Initial Notification for Compression Ignition Engines

Dear Director,

Enclosed please find Notification Forms for Facility Number 23-01-058, from Iowa American Water Co. Clinton District.

Preliminarily, the Clinton District is reporting two Non-Emergency generators. After further review of potential retrofitting expenses and annual operating costs, we will be sure to contact you should we desire to change the above noted declarations of generator classification.

If you have any questions, or need clarification of information, please contact me at 563-322-8814 xt.3.

Sincerely,

Brent A. Earley  
Water Quality Supervisor  
Iowa American Water Company



Operations Center  
5201 Grand Avenue  
Davenport, IA. 52807

P 563-322-8814 ext 3  
F 563-322-2190

<http://www.amwater.com/iaaw/>

REC'D

AUG 31 2010

APCC

August 26, 2010

Air and Waste Management Division  
U.S. Environmental Protection Agency  
901 N. 5<sup>th</sup> Street  
Kansas City, KS 66101  
Attn: Director

RE: Initial Notification for Compression Ignition Engines

Dear Director,

Enclosed please find Notification Forms for Facility Numbers 82-01-125 and 82-01-126, from Iowa American Water Co. Davenport District.

I am also submitting a form for an emergency only generator that is >300 HP but <400 HP, thus it was not previously permitted, nor given a facility number grouping. Based on guidance from Mr. Theilen, IDNR, I gave this unit the same Facility Number as the closest units.

Preliminarily, the Davenport District is reporting three Non-Emergency generators and two Emergency generators. After further review of potential retrofitting expenses and annual operating costs, we will be sure to contact you should we desire to change the above noted declarations of generator classification.

If you have any questions, or need clarification of information, please contact me at 563-322-8814 xt.3.

Sincerely,

Brent A. Earley  
Water Quality Supervisor  
Iowa American Water Company



IOWA DEPARTMENT OF NATURAL RESOURCES  
AIR QUALITY BUREAU

## Initial Notification for Compression Ignition Engines<sup>a</sup>

NESHAP for Reciprocating Internal Combustion Engines  
40 Code of Federal Regulations (CFR) 63.6580 – 63.6675 (Subpart ZZZZ)

### Facility Information

Name of Firm/Company:	Facility Name (if different):	Facility Number (if known):		
<i>Town American Water Co</i>	<i>Clinton District</i>	<i>23-01-058</i>		
Equipment Location - Street:	City:	State:	Zip:	
<i>2500 Industrial Park Drive</i>	<i>Carmanche</i>	<i>IA</i>	<i>52730</i>	
Mailing Address (if different):	City:	State:	Zip:	
<i>2020 Manufacturing Court</i>	<i>Clinton</i>	<i>IA</i>	<i>52732</i>	
Person to Contact:	Phone number:	Email (if available):		
<i>David Hanson</i>	<i>563-242-9102</i>	<i>David.Hanson@AMWater.com</i>		

This facility is a (please choose one):

- ☐ Major source: potential or actual emissions greater than 10 tons of any single hazardous air pollutant (HAP) or 25 tons of a combination of HAP
- ☒ Area source: potential and actual emissions below major source levels

### Identification of Standard

- ☒ Yes, this facility is subject to 40 CFR Part 63, Subpart ZZZZ, *National Emission Standards for Hazardous Air Pollutants for Reciprocating Internal Combustion Engines (RICE NESHAP)*:

<sup>a</sup> This is an example of the type of information that must be submitted to fulfill the Initial Notification requirement of 40 CFR 63, Subpart ZZZZ. You may submit the information in another form or format, or you may use this form.